

Town Manager's Report
JULY 2014
Prepared by David Haller

Streets:

- Staff repaired a few parking meters.
- Staff hung four new hanging baskets at the square.
- Staff installed a new street light sensor type.
- Staff trimmed brush along guardrail on Creamery Rd.

Water:

- Rainbow Lake is now 2.5" below the spillway level.
- The roughing filters are being backwashed one time a day and the DE filters are being done once a week.
- Our wells are down an average of 7.25 feet from May 2011 levels.
- Water production and consumption. We produced and purchased an average of 339,692 GPD. We consumed an average of 309,337 GPD.

The difference is "Backwash Water" ... (8.9%). We purchased 442,450 gallons of water from MSM this month.

- 43.0% of this water came from wells.
- 4.2% of this water came from Mt. St. Mary's.
- 52.8% of this water came from Rainbow Lake.

Wastewater:

- The overland flow treatment system is shut-down for the season.
- We received about 5.0 inches of precipitation this month (the average is 3.6 inches).
 - We have a precipitation **SURPLUS** of 13.2" over the last six months. The average precipitation for the period from February 1 thru July 31 is 23.2". We have received 36.4" for that period.
- Wastewater Treatment:
 - We treated an average of 295,000 GPD (consumed 309,337 GPD) which means that 0.0% of the wastewater treated this month was "wild water".
 - We had no spills of untreated sewerage in the month of July.
 - We did not exceed the plant's design capacity on any days in the month of July.

Trash: Trash pickup will remain Mondays for the remainder of the month of August

Parks:

- A Contractor and staff trimmed trees in Community and Memorial Parks.
- A Contractor trimmed some trees in Emit Gardens Park.
- Staff has installed a new baby swing.
- Staff has performed standard mowing and trimming in the parks.

I Recently Attended the Following Meetings:

- 07/24 Met with HR Consultants related to job descriptions
- 07/29 Met with staff to review several zoning issues